

Appendix G: Potable Water Letter

Drillwell Enterprises

4994 Polkey Road
Duncan, V9L 6W3, B.C.




Phone: (800) 746-7444
Fax: (250) 746-8404
Email: drill@drillwell.com



Re: LOT 3, PLAN VIP72026, SECTION 84&88, SOOKE LAND DISTRICT PID: 024-994-944

The drilled wells in this area are primarily in bedrock and although they tend to be lower yield, most are adequate domestic supplies. Drilled wells in this area range from 100' to 600' deep and produce up to 7 gallons per minute (GPM) with most in the 200' to 450' range producing 0.5-3GPM.



500 Gallons per day is often considered a luxurious domestic supply for indoor water use and those mindful of their water usage often find a well producing 0.25GPM (360 Gallons per day) will meet their needs when they have storage to meet peak demands.

There are some unsuccessful wells to the southwest of the parcel and at some point (off map) the odds of a successful well appear to drop significantly. Based on the information available it seems likely adequate domestic supplies will be possible on the subject property similar in depth and yield to those surrounding. In the unfortunate event a drilled well was unsuccessful it is likely that hydrofracturing it or exploring again some distance away could provide an adequate water supply.

Best regards,

Colin Slade